



Environmental

Geotechnical

Building Sciences

Construction Testing
& Inspections

Telephone

(866) 217.7900
(705) 742.7900

Facsimile

(705) 742.7907

Website

cambium-inc.com

Mailing Address

P.O. Box 325,
Peterborough, Ontario
Canada, K9J 6Z3

Locations

Peterborough
Kingston
Barrie
Ottawa
Whitby

Laboratory

Peterborough



May 14, 2026

Prince Edward County Lakeside Retreat Inc.
467 County Road 19, Ameliasburgh
K0K 1A0

Attn: Anthony Deonarain

Re: 467 County Road 19, Ameliasburgh – Sewage Systems
Cambium Reference: 02630848.000

Dear Anthony Deonarain,

Prince Edward County Lakeside Retreat Inc. (Client) retained Cambium Inc. (Cambium) to describe the sewage systems serving the property at 467 County Road 19, Ameliasburgh, Ontario (Site).

It is understood that the Client is pursuing a zoning bylaw amendment to allow the property to be utilized year-round.

In 2018, Cambium, on behalf of the property owner prepared an application and obtained a Sewage Works Environmental Compliance Approval (ECA) No. 1234-B38JYW (enclosed) from the Ministry of the Environment, Conservation and Parks.

As described in the ECA, the total combined capacity of the existing sewage systems is 46,775 L/day.

Please note that sewage systems are designed based on the peak sewage flow per day. As such, utilizing the sewage systems year-round is suitable.

Regarding occupancy, our assessment was based on a maximum overnight camp occupancy of 200 attendees year round.

If you have any questions or require clarification of any aspect of this submission, please to not hesitate to contact the undersigned at (705) 740-4378.



Environmental

Geotechnical

Building Sciences

Construction Testing
& Inspections

Telephone

(866) 217.7900

(705) 742.7900

Facsimile

(705) 742.7907

Website

cambium-inc.com

Mailing Address

P.O. Box 325,
Peterborough, Ontario
Canada, K9J 6Z3

Locations

Peterborough
Kingston
Barrie
Ottawa
Whitby

Laboratory

Peterborough



May 14, 2026

Respectfully submitted,

Cambium Inc.

DocuSigned by:

5230E648B0C64BD...

Stew Dolstra, Honours, B. Sc., Dipl.
BCIN, Well Technician
Group Manager – Water and Wastewater

DocuSigned by:

C9F8935E96D14CC...

Jeremy Tracey, P.Eng.
Project Manager - Water and
Wastewater

SPD

Encl. *Statement of Qualifications & Limitations*
 ECA No. 1324-B38JYW

Signed by:



2026-05-14



Environmental

Geotechnical

Building Sciences

Construction Testing
& Inspections**Telephone**

(866) 217.7900

(705) 742.7900

Facsimile

(705) 742.7907

Website

cambium-inc.com

Mailing AddressP.O. Box 325,
Peterborough, Ontario
Canada, K9J 6Z3**Locations**Peterborough
Kingston
Barrie
Ottawa
Whitby**Laboratory**

Peterborough



May 14, 2026

STATEMENT OF QUALIFICATIONS & LIMITATIONS**Limited Warranty**

Cambium relies on its client to provide instructions on the scope of work to be performed. Cambium undertakes all work in accordance with applicable accepted industry practices and standards, and with the degree of care and skill ordinarily exercised by professionals performing similar services for similar projects in the same region. Unless required under applicable laws, other than as expressly stated herein, no other warranties or conditions, either expressed or implied, are made regarding the services, work or reports provided.

Reliance on Materials and Information

The findings, results, information and data prepared by Cambium are based on the materials, documents and information provided by the client to Cambium and on the facts, conditions and circumstances encountered by Cambium during the performance of the work. In formulating its findings, results, information and data, Cambium assumes that the information, documents and materials provided by the client to Cambium are factual, accurate and represent a true depiction of the circumstances that exist at the Project. Cambium relies on its client to inform Cambium if there are changes to any such information, documents and materials. Cambium does not review, analyze or attempt to verify the accuracy or completeness of the information, documents or materials provided by the client, other than in accordance with applicable accepted industry practice. Cambium will not be responsible for matters arising from incomplete, incorrect or misleading information or from facts or circumstances that are not fully disclosed to Cambium, are unknown by Cambium, or are otherwise concealed from Cambium during the provision of its services.

Facts, conditions, information and circumstances may vary with time and locations and Cambium's work is based on a review of such matters as they existed at the particular time and location indicated in the findings, results, information and data prepared by Cambium. No assurance is made by Cambium that the facts, conditions, information, circumstances or any underlying assumptions made by Cambium in connection with the work performed will not change after Cambium has completed its work. If any such changes occur or additional information is obtained, Cambium should be advised and requested to consider if the changes or additional information affect its work.

When preparing reports, Cambium considers applicable legislation, regulations, governmental guidelines and policies. Cambium is not qualified to advise with respect to legal matters. The presentation of information regarding applicable legislation, regulations, governmental guidelines and policies is for information purposes only and is not intended to and should not be interpreted as constituting a legal opinion concerning the work completed or conditions outlined in a report. All legal matters should be reviewed and considered by an appropriately qualified legal practitioner.

Site Assessments

A site assessment is created using data and information collected during the investigation of a site and based on conditions encountered at the time and particular locations at which fieldwork is conducted. The information, sample results and data collected represent the conditions only at the specific times at which and at those specific locations from which the information, samples and data were obtained and the information, sample results and data may vary at other locations and times. To the extent that Cambium's work considers any locations or times other than those from which information, sample results and data was specifically received, the work shall be based on a reasonable extrapolation from such information, sample results and data, but the actual conditions encountered may vary from those extrapolations.

Only conditions at the site and locations chosen for study by the client are evaluated; no adjacent or other properties are evaluated unless specifically requested and paid for by the client. Any physical or other aspects of the site chosen for study by the client, or any other matter not specifically addressed in findings, results, information and data prepared by Cambium, are beyond the scopes of the work performed by Cambium and such matters have not been investigated or addressed.

Intellectual Property Rights

Upon full payment of all fees properly owing to Cambium, the client shall have a perpetual, non-exclusive, non-transferable license (without sub-licensing rights) to use the work and reports prepared by Cambium solely for their intended purpose. For greater certainty, Cambium retains all right, title, and interest in and to the work and reports, and they may not be modified, used for other purposes, or relied upon for additional work without Cambium's prior written consent.

Reliance

Cambium's services, work and reports may be relied on by the client and its corporate directors and officers, employees, and professional advisors. Cambium is not responsible for the use of its work or reports by any other party, or for the reliance on, or for any decision which is made by any party using the services or work performed by or a report prepared by Cambium without Cambium's express written consent. Any party that relies on services or work performed by Cambium or a report prepared by Cambium without Cambium's express written consent does so at its own risk. No report of Cambium may be disclosed or referred to in any public document without Cambium's express prior written consent. Cambium specifically disclaims any liability or responsibility to any such party for any loss, damage, expense, fine, penalty or other such thing which may arise or result from the use of any information, recommendation or other matter arising from the services, work or reports provided by Cambium.

Limitation of Liability

Potential liability to the client arising out of the report is limited to an amount equal to the fees paid to Cambium for the preparation of the report. Cambium shall only be liable for direct damages to the extent caused by Cambium's negligence and/or breach of contract. Cambium shall not be liable for indirect, consequential, aggravated or punitive damages and the client expressly waives the right to claim for such damages.

Personal Liability

The client expressly agrees that Cambium employees shall have no personal liability to the client with respect to a claim, whether in contract, tort and/or other cause of action in law. Furthermore, the client agrees that it will bring no proceedings nor take any action in any court of law against Cambium employees in their personal capacity.



Ministry of the Environment, Conservation and Parks
Ministère de l'Environnement, de la Protection de la nature et des Parcs

ENVIRONMENTAL COMPLIANCE APPROVAL

NUMBER 1324-B38JYW
Issue Date: August 3, 2018

Greek Orthodox Metropolis of Toronto (Canada)
467 County Road No. 19
Prince Edward, Ontario
K0K 1A0

Site Location: Ignite Camp and Retreat Centre
467 County Road 19 , Ameliasburgh
Prince Edward County,
K0K 1A0

You have applied under section 20.2 of Part II.1 of the Environmental Protection Act, R.S.O. 1990, c. E. 19 (Environmental Protection Act) for approval of:

Use and operation of three (3) existing on-site sewage Works with three (3) subsurface disposal systems, previously approved by the local Health Unit known as Works C, D and F, as described in the table below, to service an existing seasonal Ignite Camp and Retreat Centre, and including some upgrades to existing pump chambers (new access risers to grade, vents and high level alarms) and septic tanks (new access risers to grade and effluent filters), redirecting sewage flow from the Chapel building to an existing septic tank D1, redirecting sewage flow from the Cottage 1 to an existing septic tank B as well as decommissioning of three (3) existing Works A, B and E, as described below:

Sewage Works	Rated Capacity [Q] [Litres per day]	Serviced Facilities
C	9,150	Pool House Change Rooms
D	7,625	Cabins 1, 2, 3, 6, 7 & 8, Chapel Bldg.
F	30,000	Main Bldg., Cooks Cabin, Cottages 1-5, Cabins 4 & 5

EXISTING WORKS C $Q = 9,150 \text{ L/d}$

The existing Works C, designed at a Rated Capacity of 9,150 L/d, servicing the existing Pool House/Change Room, previously operated under Use Permit No. C-433-88, consisting of the

following:

Existing Septic Tank C

An existing two-compartment precast concrete Septic Tank C with a capacity of 13,500 L, collecting sewage from the Pool House Change Room, and discharging via gravity to a Pump Chamber C, as described below, **to be upgraded** with two (2) new access risers to grade with watertight access covers, inlet baffle and OBC approved effluent filter rated at minimum 9,150 L/d;

Existing Pump Chamber C

An existing one-compartment precast concrete Pump Chamber C with a capacity of 3,600 L, equipped with one (1) submersible effluent pump operated on demand, discharging a dosing volume of 1,208 L within maximum 15 minutes to an existing Leaching Bed C as described below, **to be upgraded** with a vent pipe, new access riser to grade with watertight lockable access cover and audible/visual high level alarm;

Existing Raised Leaching Bed C

An existing fully raised Leaching Bed C with a total length of 75 mm dia distribution piping of 366 m, consisting of two (2) cells, each with six (6) runs at 30.5 m long at 1.6 centres, constructed in imported sand fill with a percolation time of $T = 8 \text{ min/cm}$;

EXISTING WORKS D Q = 7,625 L/d

The existing Works D, designed at a Rated Capacity of 7,625 L/d, servicing the existing Cabins 1, 2, 3, 6, 7, 8 and Chapel Building (200 seats), previously operated under Use Permit No. P-79-77, and consisting of the following:

Existing Septic Tank D1

An existing two-compartment precast concrete Septic Tank D1 with a capacity of 4,500 L, collecting sewage from the Cabins 6 and 7 and **redirected flow from the Chapel Building**, and discharging via gravity to a Pump Chamber D2, as described below, **to be upgraded** with two (2) new access risers to grade with watertight access covers, inlet baffle and OBC approved effluent filter;

Existing Septic Tank D2

An existing two-compartment precast concrete Septic Tank D2 with a capacity of 4,500 L, collecting sewage from the Cabins 1, 2, 3 and 8, and discharging via gravity to a Pump Chamber D2, as described below, **to be upgraded** with two (2) new access risers to grade with watertight access covers, inlet baffle and OBC approved effluent filter;

Existing Pump Chamber D1

An existing one-compartment precast concrete Pump Chamber D1 with a capacity of 4,500 L, collecting sewage from Cabin 6 and discharging to the Septic Tank D1, described above, equipped with one (1) submersible sewage pump operated on demand, **to be upgraded** with a vent pipe, new access riser to grade with watertight lockable access cover and audible/visual high level alarm;

Existing Pump Chamber D2

An existing one-compartment precast concrete Pump Chamber D2 with a capacity of 3,600 L, equipped with one (1) submersible effluent pump operated on demand, discharging a dosing volume of 1,007 L within maximum 15 minutes to an existing Leaching Bed D as described below, **to be upgraded** with a vent pipe, new access riser to grade with watertight lockable access cover and audible/visual high level alarm;

Existing Raised Leaching Bed D

An existing fully raised Leaching Bed D with a total length of 75 mm dia distribution piping of 305 m, consisting of ten (10) runs at 30.5 m long at 1.6 centres, constructed in imported sand fill with a percolation time of $T = 8 \text{ min/cm}$;

EXISTING WORKS F

Q = 30,000 L/d

The existing Works F, designed at a Rated Capacity of 30,000 L/d, servicing the existing Main Building, Cooks Cabin, Cottages 1-5 and Cabins 4 and 5, previously operated under Use Permit No. C234-95, consisting of the following:

Existing Septic Tank A

An existing two-compartment precast concrete Septic Tank A with a capacity of 9,092 L, collecting sewage from the Main Building and Cooks Cabin, and discharging via gravity to a Pump Chamber A, as described below, **to be upgraded** with two (2) new access risers to grade with watertight access covers, inlet baffle and OBC approved effluent filter;

Existing Septic Tank B

An existing two-compartment precast concrete Septic Tank B with a capacity of 3,600 L, collecting sewage from the Cottages 1, 2, 3, 4 and 5, and discharging via gravity to a Pump Chamber F, as described below, **to be upgraded** with two (2) new access risers to grade with watertight access covers, inlet baffle and OBC approved effluent filter;

Existing Septic Tank G

An existing two-compartment precast concrete Septic Tank G with a capacity of 6,150 L, collecting sewage from the Cabin 4, and discharging via gravity to a Pump Chamber G, as described below, **to be upgraded** with two (2) new access risers to grade with watertight access covers, inlet baffle and OBC approved effluent filter;

Existing Septic Tank H

An existing two-compartment precast concrete Septic Tank H with a capacity of 6,150 L, collecting sewage from the Cabin 5, and discharging via gravity to a Pump Chamber G, as described below, **to be upgraded** with two (2) new access risers to grade with watertight access covers, inlet baffle and OBC approved effluent filter;

Existing Pump Chamber A

An existing one-compartment precast concrete Pump Chamber A with a capacity of 1,138 L, collecting sewage from Septic Tank A and discharging to a Pump Chamber F, described below, equipped with two (2) submersible sewage pumps operated alternatively on demand, **to be upgraded** with a vent pipe, new access riser to grade with watertight lockable access cover and audible/visual high level alarm;

Existing Pump Chamber B

An existing one-compartment precast concrete Pump Chamber b with a capacity of 2,350 L, equipped with one (1) submersible effluent pump operated on demand, collecting sewage from Cottage 1 and discharging to a Septic Tank B, as described below, **to be upgraded** with a vent pipe, new access riser to grade with watertight lockable access cover and audible/visual high level alarm;

Existing Pump Chamber G

An existing one-compartment precast concrete Pump Chamber G with a capacity of 2,700 L, equipped with one (1) submersible effluent pump operated on demand, discharging to a Pump Chamber F, as described below, **to be upgraded** with a vent pipe, new access riser to grade with watertight lockable access cover and audible/visual high level alarm;

Existing Pump Chamber F

An existing one-compartment precast concrete Pump Chamber F with a capacity of 9,092 L, equipped with two (2) submersible effluent pumps operated alternatively on demand, discharging a dosing volume of 2,475 L within maximum 15 minutes to an existing Leaching Bed F as described below, equipped with a vent pipe, access riser to grade with watertight lockable access cover and audible/visual high level alarm;

Existing Raised Leaching Bed F

An existing fully raised Leaching Bed F with a total length of 75 mm dia distribution piping of 750 m, consisting of total of thirty (30) runs at 25 m long at 1.6 centres installed within five (5) cells (six runs per cell), constructed in imported sand fill with a percolation time of $T = 5$ min/cm, and complete with a sand mantle made of imported soil with percolation time of $T = 5$ min/cm, trapezoid shaped and contact area of 4,442 m²;

all in accordance with Supporting Documentation submitted to the Ministry as listed in the **Schedule A** in this Approval.

For the purpose of this environmental compliance approval, the following definitions apply:

1. "Approval" means this entire document and any schedules attached to it, and the application;
2. "Director" means a person appointed by the Minister pursuant to section 5 of the EPA for the purposes of Part II.1 of the EPA;
3. "District Manager" means the District Manager of the Kingston District Office;
4. "EPA" means the *Environmental Protection Act* , R.S.O. 1990, c.E.19, as amended;
5. "Ministry" means the ministry of the government of Ontario responsible for the EPA and OWRA and includes all officials, employees or other persons acting on its behalf;
6. "Owner" means Greek Orthodox Metropolis of Toronto (Canada) and its successors and assignees;
7. "OWRA" means the *Ontario Water Resources Act* , R.S.O. 1990, c. O.40, as amended;
8. "Rated Capacity" means design daily sanitary sewage flow for which the Works are approved to handle;
9. "Works" means the sewage works described in the Owner's application, and this Approval.

You are hereby notified that this environmental compliance approval is issued to you subject to the terms and conditions outlined below:

TERMS AND CONDITIONS

1. GENERAL PROVISIONS

1. The Owner shall ensure that any person authorized to carry out work on or operate any aspect of the

Works is notified of this Approval and the conditions herein and shall take all reasonable measures to ensure any such person complies with the same.

2. Except as otherwise provided by these Conditions, the Owner shall design, build, install, operate and maintain the Works in accordance with the description given in this Approval, the application for approval of the works and the submitted supporting documents and plans and specifications as listed in this Approval.
3. Where there is a conflict between a provision of any submitted document referred to in this Approval and the Conditions of this Approval, the Conditions in this Approval shall take precedence, and where there is a conflict between the listed submitted documents, the document bearing the most recent date shall prevail.
4. Where there is a conflict between the listed submitted documents, and the application, the application shall take precedence unless it is clear that the purpose of the document was to amend the application.
5. The requirements of this Approval are severable. If any requirement of this Approval, or the application of any requirement of this Approval to any circumstance, is held invalid or unenforceable, the application of such requirement to other circumstances and the remainder of this Approval shall not be affected thereby.

2. CHANGE OF OWNER

1. The Owner shall notify the District Manager and the Director, in writing, of any of the following changes within 30 days of the change occurring:
 - a. change of Owner;
 - b. change of address of the Owner;
 - c. change of partners where the Owner is or at any time becomes a partnership, and a copy of the most recent declaration filed under the *Business Names Act* , R.S.O. 1990, c.B17 shall be included in the notification to the District Manager;
 - d. change of name of the corporation where the Owner is or at any time becomes a corporation, and a copy of the most current information filed under the *Corporations Information Act* , R.S.O. 1990, c. C39 shall be included in the notification to the District Manager;
2. In the event of any change in ownership of the Works, other than a change to a successor municipality, the Owner shall notify in writing the succeeding owner of the existence of this Approval, and a copy of such notice shall be forwarded to the District Manager and the Director.

3. CONSTRUCTION

1. The Owner shall ensure that the proposed upgrades to the Works are supervised by a licensed installer, as defined in the *Ontario Building Code* or a Professional Engineer, as defined in the *Professional Engineers Act* .
2. Upon completing all upgrades to the Works, the Owner shall prepare a statement, certified by a Professional Engineer, that those upgrades are constructed in accordance with this Approval, and upon request, shall make the written statement available for inspection by Ministry staff.
3. The Owner shall properly abandon any portion of unused existing sewage Works (A, B & E) , as directed below, and upon completion of decommissioning report in writing to the District Manager.
 - a. any sewage pipes leading from building structures to unused sewage Works components shall be disconnected and capped;
 - b. any unused septic tanks, holding tanks and pump chambers have to be completely emptied of its content by a licensed hauler and either be removed, crushed and backfilled, or be filled with granular material;
 - c. if the area of the existing leaching bed is going to be used, all distribution pipes and surrounding material have to be removed by a licensed hauler and disposed off site to the approved waste disposal site; otherwise the existing leaching bed can be left intact after disconnecting, if there are no other plans to use the area for other purposes;

4. MONITORING AND RECORDING

1. The Owner shall employ any measurement devices to accurately measure quantity of effluent being discharged to each individual subsurface disposal system for each Works (C, D and F), including but not limited to water/wastewater flow meters, event counters, running time clocks, or electronically controlled dosing, and shall record the daily volume of effluent being discharged to the subsurface disposal system.
2. The Owner shall retain for a minimum of five (5) years from the date of their creation, all records and information related to or resulting from the Operation and Maintenance activities required by this Approval.

5. OPERATIONS AND MAINTENANCE

1. The Owner shall prepare an operations manual that includes, but not necessarily limited to, the

following information:

- a. operating procedures for routine operation of all the Works;
 - b. inspection programs, including frequency of regular inspection for all the Works, and the methods or tests employed to detect when maintenance is necessary;
 - c. maintenance programs, including the frequency of maintenance for all the Works; copies of maintenance contracts for any routine inspections & pump-outs should be included;
 - d. procedures for the inspection and calibration of monitoring equipment;
 - e. a spill prevention control and countermeasures plan, consisting of contingency plans and procedures for dealing with equipment breakdowns, potential spills and any other abnormal situations, including notification of the District Manager; and
 - f. procedures for receiving, responding and recording public complaints, including recording any follow-up actions taken.
 - g. emergency plan in the event of sewage Works failure;
2. The Owner shall ensure that regular Works inspections are done using a standard equal to or greater than the inspection protocols of the "On-Site Sewage Maintenance Inspection " document dated March 2011 as amended from time to time, developed by the Ministry of Municipal Affairs and Housing.
 3. The Owner shall maintain the operations manual current and retain a copy at the location of the Works for the operational life of the Works. Upon request, the Owner shall make the manual available to Ministry staff.
 4. The Owner shall ensure that all septic tanks are pumped out every 3-5 years or when the tank is 1/3 full of solids and the effluent filters are cleaned out at minimum once a year or more often if required.
 5. The Owner shall ensure that grass-cutting is maintained regularly over all the subsurface disposal beds, and the drainage operations in all beds are visually observed on a monthly basis. In the event a break-out is observed from a subsurface disposal bed, the Owner shall ensure that the sewage discharge to the bed is discontinued and the incident immediately reported verbally to the District Manager, followed by a written report within one (1) week. The Owner shall ensure that during the time remedial actions are taking place the sewage generated at the site shall not be allowed to discharge to a surface water body or to the environment, and safely collected and disposed off through a licensed waste hauler to an approved waste disposal site.
 6. The Owner shall prohibit the construction of any structures such as decks, patios or sheds over the disposal fields and ensure that adequate steps are taken to ensure that the area of the Works are

protected from all forms of vehicle traffic.

7. The Owner shall employ for the overall operation of the Works a person who possesses the level of training and experience sufficient to allow safe and environmentally sound operation of the Works.

6. REPORTING

1. In addition to the obligations under Part X of the *Environmental Protection Act*, the Owner shall, within 10 working days of the occurrence of any reportable spill as defined in Ontario Regulation 675/98, loss of any product, by-product, intermediate product, oil, solvent, waste material or any other polluting substance into the environment, submit a full written report of the occurrence to the District Manager describing the cause and discovery of the spill or loss, clean-up and recovery measures taken, preventative measures to be taken and schedule of implementation.
2. The Owner shall, upon request, make all manuals, plans, records, data, procedures and supporting documentation available to Ministry staff and Source Protection Authority.
3. The Owner shall prepare a performance report on an annual basis and keep them at the operating authority's office. The first such report shall cover the first annual period following the commencement of operation of the Works and subsequent reports shall be submitted to cover successive annual periods following thereafter. The reports shall contain, but shall not be limited to, the following information:
 - a. an overview of the success and adequacy of all Works, including a Contingency Plan.
 - b. a description of any operating problems encountered and corrective actions taken at any sewage Works;
 - c. a record of maintenance carried out on any major structure, equipment, apparatus, mechanism or thing forming part of any Works including but not limited to: records of effluent filters cleaning, septic tank pump-outs, pumps replacement, visual inspections of all subsurface disposal beds, etc.;
 - d. a summary and interpretation of all daily flow data and results achieved in not exceeding the maximum daily sewage flow discharged into each one of the subsurface disposal system;
 - e. a summary of any complaints received during the reporting period and any steps taken to address the complaints;
 - f. a summary of all spill or abnormal discharge events;
 - g. any other information the District Manager requires from time to time;

The reasons for the imposition of these terms and conditions are as follows:

1. Condition 1 is imposed to ensure that the Works are built and operated in the manner in which they were described for review and upon which approval was granted. This condition is also included to emphasize the precedence of Conditions in the Approval and the practice that the Approval is based on the most current document, if several conflicting documents are submitted for review. The condition also advises the Owners their responsibility to notify any person they authorized to carry out work pursuant to this Approval the existence of this Approval.
2. Condition 2 is included to ensure that the Ministry records are kept accurate and current with respect to the approved works and to ensure that subsequent owners of the Works are made aware of the Approval and continue to operate the Works in compliance with it.
3. Condition 3 is included to ensure that the works are constructed, and may be operated and maintained such that the environment is protected and deterioration, loss, injury or damage to any person or property is prevented.
4. Condition 4 is included to enable the Owner to evaluate and demonstrate the performance of the Works, on a continual basis, so that the Works are properly operated and maintained at a level which is consistent with the design objectives specified in the Approval and that the Works does not cause any impairment to the receiving watercourse.
5. Condition 5 is included to require that the Works be properly operated, maintained, and equipped such that the environment is protected. As well, the inclusion of an operations manual, maintenance agreement with the manufacturer for the treatment process/technology and a complete set of "as constructed" drawings governing all significant areas of operation, maintenance and repair is prepared, implemented and kept up-to-date by the owner and made available to the Ministry. Such information is an integral part of the operation of the Works. Its compilation and use should assist the Owner in staff training, in proper plant operation and in identifying and planning for contingencies during possible abnormal conditions. The manual will also act as a benchmark for Ministry staff when reviewing the Owner's operation of the work.
6. Condition 6 is included to provide a performance record for future references, to ensure that the Ministry is made aware of problems as they arise, and to provide a compliance record for all the terms and conditions outlined in this Approval, so that the Ministry can work with the Owner in resolving any problems in a timely manner.

Schedule A

1. Application for Environmental Compliance Approval submitted by Stewart Dolstra of Cambium Inc. received on March 12, 2018 for the approval of use and operation of three (3) existing sewage Works (C, D & F) with some minor modifications and decommissioning of three (3) Works (A, B & E) not being used, including Environmental Study Report, design report, final plans and specifications.

In accordance with Section 139 of the Environmental Protection Act, you may by written Notice served upon me, the Environmental Review Tribunal and in accordance with Section 47 of the Environmental Bill of Rights, 1993, S.O. 1993, c. 28 (Environmental Bill of Rights), the Environmental Commissioner, within 15 days after receipt of this Notice, require a hearing by the Tribunal. The Environmental Commissioner will place notice of your appeal on the Environmental Registry. Section 142 of the Environmental Protection Act provides that the Notice requiring the hearing shall state:

- a. The portions of the environmental compliance approval or each term or condition in the environmental compliance approval in respect of which the hearing is required, and;
- b. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

The Notice should also include:

1. The name of the appellant;
2. The address of the appellant;
3. The environmental compliance approval number;
4. The date of the environmental compliance approval;
5. The name of the Director, and;
6. The municipality or municipalities within which the project is to be engaged in.

And the Notice should be signed and dated by the appellant.

This Notice must be served upon:

The Secretary*
Environmental Review Tribunal
655 Bay Street, Suite 1500
Toronto, Ontario
M5G 1E5

AND

The Environmental Commissioner
1075 Bay Street, Suite 605
Toronto, Ontario
M5S 2B1

AND


The Director appointed for the purposes of
Part II.1 of the Environmental Protection Act
Ministry of the Environment,
Conservation and Parks
135 St. Clair Avenue West, 1st Floor
Toronto, Ontario
M4V 1P5

*** Further information on the Environmental Review Tribunal's requirements for an appeal can be obtained directly from the Tribunal at: Tel: (416) 212-6349, Fax: (416) 326-5370 or www.ert.gov.on.ca**

This instrument is subject to Section 38 of the Environmental Bill of Rights, 1993, that allows residents of Ontario to seek leave to appeal the decision on this instrument. Residents of Ontario may seek leave to appeal within 15 days from the date this decision is placed on the Environmental Registry. By accessing the Environmental Registry at www.ebr.gov.on.ca, you can determine when the leave to appeal period ends.

The above noted activity is approved under s.20.3 of Part II.1 of the Environmental Protection Act.

DATED AT TORONTO this 3rd day of August, 2018



Fariha Pannu, P.Eng.

Director

appointed for the purposes of Part II.1 of the
Environmental Protection Act

BM/

c: Area Manager, MECP Belleville

c: District Manager, MECP Kingston - District

Bernie Taylor, P.Eng., Cambium Inc.

Amy Dickens, Source Water Protection Coordinator, Quinte Conservation, Belleville